

FIRE EVACUATION AND BELL TEST POLICY

At The Centre, our overall aim is to minimise the risks to pupils and staff in the event of a fire. Safety and preservation of life is our priority and will override all other considerations. We ensure that precautions are taken to avoid and reduce effects of a fire outbreak, procedures are in place for evacuating children safely and that the fire alarm system is in operation.

Responsibility

Person	Responsibility	Exit Route
Manager/ Supervisor	 Overall responsibility for fire safety matters; Implementation of fire safety matters; Make sure that all the children evacuate the premises safely; Ensure that staff and pupil training take place and monitor the standard of fire precautions maintained; Ensure all new staff are inducted and fire evacuation procedures are explained; Ensure that a fire evacuation drill is undertaken each half term; that fire action notices are kept up to date. 	Main exit, if safe
Lunch	 Ensure that they are fully aware of all fire procedures; Ensure the safe evacuation of all pupils for whom they are responsible; Ensure that no-one is left in the class room, toilets or corridor and conduct a roll call outside at the Assembly point; Ensure that door vision panels and fire exits are kept clear and fire doors are kept shut; Ensure that pupils for whom they are responsible are informed of the correct fire procedures. 	Nearest Exit, if safe
Admin	 Call the emergency services if it is a genuine fire; Ensure the office and staff room is evacuated; Collect the visitor's book, and all the registers; and go directly to the assembly point; Distribute registers at assembly point staff and assist in the checking of the registers and staff registers. 	Main exit, if safe
Caretaker	 To carry out fire bell test and visual check of panel for fault every Tue morn; Ensure fire safety equipment is maintained; Check fire doors and Fire extinguishers weekly 	

Approved: September 2020 - Date of Review: September 2021



Procedure

- Each session, the attendance register shall be taken;
- Each session, staff will sign-in when they arrive and any staff leaving the premises shall signout;
- Any child leaving the premises shall be marked off the register;
- All visitors shall sign the visitors book on entry and sign-out when leaving.

Fire Evacuation

Fire Drill

- A fire drill shall be carried out at least once every term;
- When the bell rings (which will be a continuous ringing sound), the children shall be quickly lined up in a single file and evacuated through the nearest exit;
- Whilst staff are leaving the hall through the fire exit they shall check the toilets as they pass;
- Staff shall conduct a roll call by taking a register to see if all children, staff and visitors are present;
- If all children, staff and visitors are present, re-enter the building if it is safe to do so.
- SMT to record date, time, duration of drill and sign off.

Actual Fire/Emergency

- When the fire bell rings quickly line up the children and leave premises from the nearest fire exit;
- SMT/Admin (or any member of staff in their absence) shall call the fire brigade if safe to do so or else use the nearest external telephone;
- Close all windows, doors and switch off electrical items, if safe to do so;
- Under no circumstances, should children or staff collect belongings;
- · Assemble the children far end of the playground;
- Admin will take student register, staff sign in sheet and visitors book outside. A head count will be done, and register will be taken by the class tutor;
- SMT will conduct a roll call to see if all staff and visitors are present;
- Do not attempt to re-enter the building;
- If someone is missing, the building shall not be re-entered, but information shall be given to the fire brigade for them to make a search.

Approved: September 2020 - Date of Review: September 2021



Fire bell test

- Fire bell test shall be carried out once a week on every Tuesday at 9:00 am;
- Sound the alarm for approximately 5 seconds;
- Each week a different call point shall be activated;
- Findings are recorded at the end of the test;
- If the bell malfunctions or a fault light appears on the panel, it shall be reported immediately for repairs.

Approved: September 2020 - Date of Review: September 2021